

**Approved Minutes of Emergency Meeting  
of  
Quonochontaug Central Beach Fire District  
Public Works Committee  
August 24, 2019 at 8:30 a.m.  
Charlestown Police Department  
4901 Old Post Rd, Charlestown, RI 02813**

**Present:**, Tom Frost, Greg Reppucci, Richard Campbell, Steve Peet, Jim Finn, Vincent Reppucci, Jim Montstream, George Prior, Bob Frazier.

Absent: Fig Newton.

1. Meeting called to order 8:30 AM
2. By unanimous vote it was agreed that this meeting was necessary on less than 48 hours' notice to the public due to receipt of RIDOH Level 2 assessment report of our Public Water System and necessity of prompt responsive action to protect public in light of continuing Boil Water Advisory with respect to the system.
3. RIDOH Level 2 report was reviewed and discussion ensued
  - a. PW Committee will place signs around the wellhead to limit access by the public, especially dogs and the leaving of trash.
  - b. Cross Contamination Control Certificate will be signed and implemented
  - c. Remaining issues will be discussed and coordinated with NWSI. Chair will contact NWSI and coordinate on Monday am 8/26
4. Level 2 assessment has reclassified our two wells as Ground Water Under the direct influence of surface water (GUDI) and offered options to reverse this designation. Regardless RIDOH will mandate that we utilize a 4 log disinfection system, chemical or otherwise, if the well classifications remains as GUDI after 1 year or if monthly sampling return TC+ and trigger a second level 2 which does not find a correctable sanitary defect. Much discussion ensued on this point and a motion was made as follows, seconded and approved unanimously
  - a. **PW Committee proceed immediately to initiate development and design of a 4 log water disinfection systems which would satisfy RIDOH requirements and to prepare for installation if required.**
5. Meeting adjourned @ 8:57

Respectfully submitted VReppucci